



ई-मेल ee_rbi02_@yahoo.com

कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय
उ०प्र० जल निगम(ग्रामीण), अमेठी

फोन-9473942559

पत्रांक 104 / प्रयोगशाला / 04

दिनांक 30/01/2026

सेवा में,

The Principal
St. Mary'S English Medium School,
Parsawan- Amethi (U.P.) 227405

विषय:- पेयजल प्रमाण पत्र निर्गत कराये जाने के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय के पत्रांक 12677/26 दिनांक 22-01-2026 के संदर्भ में St. Mary'S English Medium School, Parsawan- Amethi के लिये पेयजल से सम्बन्धित प्रमाण पत्र निर्गत करने का अनुरोध किया गया है।

उक्त के सम्बन्ध में विद्यालय द्वारा उपलब्ध कराये गये R.O. के जल नमूने की 14 पैरामीटर की जांच जनपद स्तरीय प्रयोगशाला उ०प्र० जल निगम (ग्रामीण) अमेठी में की गयी, जिसमें पानी की गुणवत्ता संतोषजनक पायी गयी है।

संग्लनक:- उपरोक्तानुसार।

भवदीय

(अनिल कुमार राव)
अधिशासी अभियन्ता

पृ०सं०

दिनांक

प्रतिलिपि:-

1. सम्बन्धित सहायक अभियन्ता/जूनियर इंजीनियर (प्रयोगशाला) अमेठी।
2. खण्ड लेखाकार/मुख्य लिपिक/संगणक।

अधिशासी अभियन्ता



कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय
उ०प्र० जल निगम(ग्रामीण), अमेठी

ई-मेल : ee_rbi02_@yahoo.com

फोन-9473942559

पत्रांक

दिनांक

संख्या में,

The Principal
St. Mary'S English Medium School,
Parsawan- Amethi (U.P.) 227405

विषय:- पेयजल प्रमाण पत्र निर्गत कराये जाने के सम्बन्ध में।

सहायक,

उपरोक्त विषयक आपके कार्यालय के पत्रांक 12677/26 दिनांक 22-01-2026 के संदर्भ में St. Mary'S English Medium School, Parsawan- Amethi के लिये पेयजल से सम्बन्धित प्रमाण पत्र निर्गत करने का अनुरोध किया गया है।

उक्त के सम्बन्ध में विद्यालय द्वारा उपलब्ध कराये गये R.O. के जल नमूने की 14 पैरामीटर की जांच जनपद स्तरीय प्रयोगशाला उ०प्र० जल निगम (ग्रामीण) अमेठी में की गयी, जिसमें पानी की गुणवत्ता संतोषजनक पायी गयी है।

संगलनक:- उपरोक्तानुसार।

भवदीय

(अनिल कुमार राव)
अधिशासी अभियन्ता

पृ०सं० 104 / प्रयोगशाला 110 / 04

दिनांक 30/01/2026

प्रतिलिपि:-

1. सम्बन्धित सहायक अभियन्ता/जूनियर इंजीनियर (प्रयोगशाला) अमेठी।
2. खण्ड लेखाकार/मुख्य लिपिक/संगणक।

अधिशासी अभियन्ता



Test Report

DISTRICT LEVEL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM(Rural), AMETHI



Certificate No. IC 13416

Rept No	Test Report/Exe Eng Con Div/ Chemical Test 386/2025-26	Issue Date	27/01/2026	Page No	01
ULR NO	TC-134162600000064F				

Customer Details	
Office Name and Address	St. Mary'S English Medium School ,Parsawan- Amethi
Ret Letter No & Date	

District	Amethi	Block	Amethi
Gram Panchayat	Mahmoodpur	Village	Mahmoodpur
Habitation	Near Polytechnic	Location	
Water Source	R.O.	Sample Code	A/23/01/2404
Quantity of Sample	1.0 Litter	Date of Sample Collection	23-01-2026
Receiving Date	23-01-2026	Sample Collector	Arvind Shrivastav
Sample Depositer	Arvind Shrivastav	Sampling Method Used	IS:17614-P-1:2021
Analysis Start Date	24-01-2026	Analysis Completion Date	24-01-2026

Environmental Condition	
Temperature	25±3 oC
Humidity	50±15%

S No	Parameter	Units	Observed Value	Technical Data of Analysis		Ref Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Turbidity	(NTU)	0.09	1.00	5.00	IS 3025 (Part 10) 2023
2	pH Value		7.5	6.5-8.5	6.5-8.5	IS 3025 (Part 11) 2022 (Electrometric Method)
3	TDS	(mg/L)	150	500.00	2000	IS 3025 (Part 16) 2023
4	Chloride	(mg/L)	14.99	250.00	1000	IS 3025 (Part 32) 2019
5	Iron (as Fe)	(mg/L)	0.08	0.30	1	APHA 24th Edition-3500-Fe Method B(Phenanthroline 2023)
6	Sulphate (as SO4)	(mg/L)	1.4	200.00	400	APHA 24th Edition - 4500-SO4 Method E (Turbidity Method) 2023
7	Nitrate (as NO3)	(mg/L)	0.06	45.00	45	APHA 24th Edition-4500-NO3 Method D(UV-Screening Method) 2023
8	Total Alkalinity(as CaCO3)	(mg/L)	70	200.00	600	IS 3025 (Part 23) 2023
9	Total Hardness (as CaCO3)	(mg/L)	58	200.00	600	IS 3025 (Part 21) 2019
10	Calcium	(mg/L)	4.8	75.00	200	IS 3025 (Part 40) 2023
11	Magnesium	(mg/L)	11.178	30.00	100	IS 3025 (Part 46) 2023
12	Taste	Qualitative	Agreeable	-	-	IS 3025 (Part 08) 2023
13	Odour	Qualitative	Agreeable	-	-	IS 3025 (Part 05) 2018
14	Colour	Hazen	BDL	5	15	APHA 24th Edition-2120 Colour Method B(Platinum Cobalts Visual Comparison 2023)

- Note:
- 1) This certificate refers only to the particular samples (s) submitted for testing
 - 2) This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head Of Laboratory
 - 3) The test results reported in this certificate are valid at the time of and under the stated conditions of measurements
 - 4) Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified

Neha Maurya
Prepared By
Neha Maurya
(Deputy Technical Manager)

Chandra Prakash Sharma
Authorised signatory
Chandra Prakash Sharma (Technical Manager)

Laboratory Contact Details :- Name - Chandra Prakash Sharma
Mo No. - 9628474106

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 100 / यकाशााल स।० / ०५

Dated: 30/01/2026

It is certified that an inspection team headed by Shri Anshu Gupta Assistant Engineer (Name of Officers with designation) from U.P. Jal Nigam (Rural) PHED inspected the **ST. MARYS ENGLISH MEDIUM SCHOOL, PARSAWAN AMETHI 227405** (Name & Address of the school) on (date of inspection) and on the basis of Water Test Report (Attached) bearing no..... dated 27/01/2026 of NABL (PHED Lab) certified that the **ST. MARYS ENGLISH MEDIUM SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 27/01/2026 to 26/01/2027

अंशु गुप्ता
सहायक अभियन्ता
जल विभाग
उ.प्र. जल निगम (ग्रामीण)
अमेठी

Signature with Seal:
Name: (Shri Anshu Gupta)
Designation: Assistant Engineer
Name & Address of the Office/Department: U.P. Jal Nigam (Rural) Amethi

To,
**ST. MARYS ENGLISH MEDIUM SCHOOL,
PARSAWAN, AMETHI 227405**
(Name & Address of the Institution)